

T E S T C E R T I F I C A T E

CT-10-06-29- 04

- Product:** Particle boards P2 Maxx according to EN 312
Nominal thickness 6 - 60 mm
- Company:** Nolte Holzwerkstoff GmbH & Co. KG
Konrad-Nolte-Straße 40
76726 Germersheim
- Order:** Determination of the PCP and Lindan content of particle boards
according to EN 312
- Test method:** Pentachlorphenol (PCP): CEN/TR 14823/
Institute standard ihd-W 409
 γ -Hexachlorcyclohexan (Lindan): Institute standard ihd-W 410
- Test report:** test report 259013 dated June 29th, 2010
- Test result:** The particle boards P2 Maxx according to EN 312 meet the requirements on the limiting value for the content of PCP of 5 mg/kg according to the ChemVerbotsV § 1 (15). For the particle boards P2 Maxx there is no obligation for labelling according to EN 13 986 regarding the PCP-content. In addition the particle boards P2 Maxx meet the requirements on the reference value of Lindan of 0,5 mg/kg according to the „Allgemeine Güte- und Prüfbestimmungen für Möbel“ RAL-GZ 430.
- Period of validity:** This certificate is valid for the supervision period of 12 months.

Dresden, June 29th, 2010


Head of laboratory




Engineer in charge