


# TEST CERTIFICATE


**CT-10-12-14- 05**

- Product:** Particle boards Air Maxx according to EN 312  
Nominal thickness 15 - 60 mm
- Company:** Nolte Holzwerkstoff GmbH & Co. KG  
Konrad-Nolte-Straße 40  
76726 Germersheim
- Order:** Determination of the PCP and Lindan content of particle boards  
according to EN 312
- Test method:** Pentachlorphenol (PCP): CEN/TR 14823/  
Institute standard ihd-W 409  
 $\gamma$ -Hexachlorcyclohexan (Lindan): Institute standard ihd-W 410
- Test report:** test report 259013 dated December 14<sup>th</sup>, 2010
- Test result:** The particle boards Air Maxx according to EN 312 meet the requirements on the limiting value for the content of PCP of 5 mg/kg according to the ChemVerbotsV § 1 (15). For the particle boards Air Maxx there is no obligation for labelling according to EN 13 986 regarding the PCP-content.  
In addition the particle boards Air Maxx meet the requirements on the reference value of Lindan of 0,5 mg/kg according to the „Allgemeine Güte- und Prüfbestimmungen für Möbel“ RAL-GZ 430.
- Period of validity:** This certificate is valid for the supervision period of 12 months.

Dresden, December 14<sup>th</sup>, 2010



Head of laboratory



Engineer in charge